



NOTES:

- ① JOINT RESTRAINT SHALL BE BY MEGALUG OR APPROVED EQUAL.
- ② COAT ALL ANCHORAGE AS PER SPECS.
- ③ PROVIDE SAND CUSHION BETWEEN TOP OF WATERMAIN AND BOTTOM OF SEWER PIPE, MIN. DIMENSIONS AS SHOWN THIS DETAIL. (INCIDENTAL)
- ④ INSULATION TO BE 2" THICK DENSE FOAM
- ⑤ ALL FITTINGS, VALVES, HYDRANTS, AND RETAINING RODS SHALL BE PROTECTED AGAINST CORROSION BY FURNISHING AND INSTALLING 6 OZ. SACRIFICIAL ZINC ANODE CAPS MEETING THE REQUIREMENTS OF ASTM B418-88, TYPE II. CONTRACTORS SHALL INSTALL A MINIMUM OF 2 CAPS PER MECHANICAL JOINT GLAND INSTALLED.

WATERMAIN OFFSET

NOT TO SCALE

PLATE 6004

WATERMAIN OFFSET

STANDARD DETAIL

PLATE NO:

6004

APPROVED: ADOPTED BY CITY COUNCIL ON JANUARY 12, 2004

REVISED: REVISION ADOPTED BY CITY COUNCIL ON MARCH 10, 2008

REMARKS:

SAINT PETER UTILITY STANDARD DETAIL



CITY OF
Saint Peter
NICOLLET COUNTY, MINNESOTA
WHERE HISTORY & PROGRESS MEET