



SECTION A

NOTES:

1. THE CONCRETE VALLEY GUTTER SHALL BE CONSTRUCTED ON 6" AGGREGATE BASE, CL. 5 (2211) (100% CRUSHED LIMESTONE) OR CL. 5 (B) OR CL. 5 (C) RECYCLED (INCIDENTAL TO VALLEY GUTTER)
2. FOR ENTRANCES TO PRIVATE PROPERTY, THE ROADWAY PAVEMENT INSIDE THE VALLEY GUTTER SHALL BE 7" THICK CONCRETE WITH A MINIMUM 6" AGGREGATE BASE, EXTEND TO THE RIGHT-OF-WAY LINE AND BE POURED SEPARATE FROM THE VALLEY GUTTER. IF A PUBLIC ROAD ENTRANCE, THE ROADWAY PAVEMENT INSIDE THE VALLEY GUTTER SHALL BE BITUMINOUS.

CONCRETE VALLEY GUTTER

NOT TO SCALE

SAINT PETER STANDARD
PLATE 7004

CONCRETE VALLEY GUTTER

STANDARD DETAIL
PLATE NO:
7004

APPROVED: ADOPTED BY CITY COUNCIL ON JANUARY 12, 2004

REVISED: REVISION ADOPTED BY CITY COUNCIL ON FEBRUARY 27, 2017

REMARKS:

SAINT PETER UTILITY STANDARD DETAIL

